

**NUMBER OF TEMPORARY OVERVOLTAGE VIOLATIONS**

<u>Bin</u>	<u>Case 5</u>	<u>Case 5+5</u>	<u>Case 5+10</u>	<u>Case 5+20</u>
1	16	40	33	5
1.05	2033	2006	2023	1337
1.1	3987	3602	3605	3026
1.15	2960	3525	3611	2774
1.2	2780	3146	3097	2969
1.25	2229	2233	2145	2411
1.3	1414	1246	1217	1711
1.35	880	763	783	1172
1.4	634	446	462	852
1.45	329	268	273	596
1.5	237	186	156	386
1.55	127	104	104	232
1.6	93	79	90	127
1.65	35	45	47	65
1.7	6	34	41	39
1.75	0	14	10	21
1.8	0	8	9	14
1.85	0	5	8	10
1.9	0	1	14	12
1.95	0	4	10	1
2	0	1	6	0
More	0	4	16	0
Into Safty Margin	134	195	251	289
Above Equip Capability	0	15	54	23

(Applicant Ex. 199)