

ANDREW W. LORD
860.240.6180 DIRECT TELEPHONE
860.240.5723 DIRECT FACSIMILE
ALORD@MURTHALAW.COM

January 13, 2012

VIA HAND DELIVERY

Ms. Linda Roberts
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: Docket No. 189A; Lake Road Generating Company, L.P.

Dear Ms. Roberts:

I write on behalf of Lake Road Generating Company, L.P. ("Lake Road") to provide you with suggested revisions to the draft Findings of Fact in Docket No. 189A in which Lake Road requested that the Connecticut Siting Council approve the suspension of the back-up distillate fuel system on Unit 1 of the Lake Road generation facility in Killingly, Connecticut.

First, proposed Finding of Fact No. 12 states:

Lake Road would maintain DEEP air permits to allow operation of the plant on fuel oil. On July 12, 2011, Lake Road received modifications to its air permits. The permits had previously required stack testing once every five years or before 700 hours of operation on oil, whichever is longer. Based on modifications to its air permit, Lake Road will no longer have to perform stack testing for oil operation in its plant. (Lake Road 1, p. 5; Lake Road 2, R. 1: Tr. 1, p. 10)

It should state:

Lake Road would maintain DEEP air permits to allow operation of the plant on fuel oil. On July 12, 2011, Lake Road received modifications to its air permits. The permits had previously required stack testing once every five years. Based on modifications to its air permit, Lake Road will now have to perform stack testing on oil once every five years or after 700 hours of operation on oil, whichever is longer.


Ms. Linda Roberts
January 13, 2012
Page 2

Second, Lake Road understands that the Council, after a straw poll of its members, has directed staff to draft a Decision and Order to approve the request to suspend the oil-firing capabilities on Unit 1. As a point of clarification regarding proposed Finding of Fact No. 19 and as indicated in Lake Road's response to the Siting Council's Pre-hearing Interrogatory No. 2, Lake Road requests that Condition 1(c) of the Siting Council's Decision and Order in Docket No. 189 be revised as follows:

(c) The project shall operate on natural gas. Lake Road may operate using distillate fuel oil as allowed by the Department of Energy and Environmental Protection Air Permits.

If you have any questions or require additional information, please do not hesitate to contact me.

Sincerely,



Andrew W. Lord

cc: Melanie Bachman, Esq.
Ms. Christina Walsh
Service List

LIST OF PARTIES AND INTERVENORS
SERVICE LIST

Status Granted	Status Holder (name, address & phone number)	Representative (name, address & phone number)
Applicant	Lake Road Generating Company, L.P.	<p>Andrew Lord, Esq. Murtha, Cullina, Richter & Pinney CityPlace I, 185 Asylum Street Hartford, CT 06103-3469 (860) 240-6180</p> <p>Cynthia E. Vodopived, Director Health, Safety, Security and Environment EquiPower Resources Corporation One Hundred Constitution Plaza, 10th Fl. Hartford, CT 06103</p> <p>Christopher J. Curtis General Manager Lake Road Generating Company, L.P. 56 Alexander Parkway Dayville, CT 06241</p>
Party	Town of Killingly	<p>Bruce E. Benway Town Manager Town of Killingly Town Hall, 172 Main Street P.O. Box 6000 Danielson, CT 06239-6000</p>
Intervenor	Connecticut Light and Power Company	<p>Senior Counsel Northeast Utilities Service Company P.O. Box 270 Hartford, CT 06106-0270 (860) 665-3395</p>