

STATE OF CONNECTICUT

SITING COUNCIL

DOCKET NO. 424 - The Connecticut Light & Power Company application for a Certificate of Environmental Compatibility and Public Need for the Connecticut portion of the Interstate Reliability Project that traverses the municipalities of Lebanon, Columbia, Coventry, Mansfield, Chaplin, Hampton, Brooklyn, Pomfret, Killingly, Putnam, Thompson, and Windham, which consists of (a) new overhead 345-kV electric transmission lines and associated facilities extending between CL&P's Card Street Substation in the Town of Lebanon, Lake Road Switching Station in the Town of Killingly, and the Connecticut/Rhode Island border in the Town of Thompson; and (b) related additions at CL&P's existing Card Street Substation, Lake Road Switching Station, and Killingly Substation.

DOCKET 424

JULY 17, 2012

**SUPPLEMENTAL TESTIMONY OF TIMOTHY F. LASKOWSKI
AND ROGER C. ZAKLUKIEWICZ**

**CONCERNING THE NEED FOR
THE INTERSTATE RELIABILITY PROJECT**

1 **Q. Have you reviewed the draft ISO-NE report entitled “Follow-Up Analysis to**
2 **the 2011 New England East-West Solution (NEEWS) Interstate Reliability**
3 **Project Component Updated Needs Assessment” (the 2012 *Follow-Up Needs***
4 ***Analysis*), which was filed with the Council on July 10, 2012, pursuant to a**
5 **protective order that the Council has entered in this Docket?**

6 A. Yes, we have.

7

8 **Q. Did the NUSCO or National Grid planners participate in the preparation of**
9 **this report or in the design or execution of the analyses described in the**
10 **report?**

11 A. No, we did not. All of this work was performed exclusively by ISO-NE.

12

13 **Q. Why did ISO-NE undertake this “follow-up” study after publishing the 2011**
14 ***Updated Solution Study Report* in February of this year, in which ISO**
15 **reported that The Interstate Reliability Project was the optimum solution for**
16 **needs that had been under study since 2004?**

17 A. ISO-NE is required by Attachment K to its FERC-approved Open Access
18 Transmission Tariff (OATT) to update its needs assessments as new resources
19 materialize through the Forward Capacity Auction, as load forecasts change, as
20 new resources are built or committed, or if other important changes in system
21 conditions occur. If ISO-NE determines, as part of its periodic re-evaluation
22 responsibility, that a transmission project being implemented by a transmission
23 owner (TO) is no longer needed, or if a market solution that meets specific

1 viability criteria is subsequently proposed, it will direct the TO to discontinue its
2 development effort, and the TO will be entitled to recover its costs incurred to that
3 point through regional rates. ISO-NE's previous analyses were based on FCA #4
4 results and after completing those analyses in 2011, ISO-NE had adopted and
5 began to implement a new methodology for predicting future EE in load forecasts.
6 ISO-NE determined that, pursuant to Attachment K, these changes in assumptions
7 and methods, together with certain changes to the system that were planned or had
8 occurred, required a fresh look at the Interstate Reliability Project and other
9 regional projects that had not yet entered the construction stage.

10
11 **Q. What is the overall conclusion of the draft 2012 Follow-Up Needs Analysis?**

12 A. ISO-NE concluded that the results of its most recent power-flow analyses show a
13 need to:

- 14 • Reinforce the 345-kV system into West Farnum Substation for Rhode
15 Island reliability;
- 16 • Increase the transmission transfer capability from eastern New England
17 and Greater Rhode Island to western New England if additional resources
18 are available in the exporting area;
- 19 • Increase the transmission transfer capability from western New England
20 and Greater Rhode Island to eastern New England, particularly in light of
21 the retirement of the Salem Harbor units; and
- 22 • Increase the transmission transfer capability into the State of Connecticut

23 ISO-NE noted that these issues were seen in its previous needs re-analysis, to
24 which we refer in our previous testimony as the "2011 Updated Needs Report;"
25 and that the studies undertaken for the 2012 Follow-Up Needs Analysis continue
26 to show similar concerns within the 10-year planning horizon.

1 **Q. What is the status of that the draft *2012 Follow-Up Needs Analysis*?**

2 A. The draft report has been posted on the ISO-NE Planning Advisory Committee
3 (PAC) website for comment by interested stakeholders. It will also be presented
4 to the PAC at a meeting scheduled for tomorrow, July 18, 2012. Comments will
5 be received up to August 8, 2012, at which time ISO-NE will respond to the
6 comments, finalize the report, and issue a public version that has been redacted to
7 eliminate Critical Energy Infrastructure Information (CEII).

8

9 **Q. Do you expect any significant changes to be made to the draft report in light**
10 **of these comments?**

11 A. That is always possible. However, changes made to ISO-NE reports after they
12 have been posted in draft tend to concern matters of detail and not significant
13 changes.

14

15 **Q. Does the draft *2012 Follow-Up Needs Analysis* conclude that the Interstate**
16 **Reliability Project will meet the continuing needs documented in that report?**

17 A. No. ISO-NE states in the report that it is working on a second follow-up study to
18 confirm that the transmission solutions outlined in the *2011 Updated Solution*
19 *Study Report* continue to meet the identified needs.

20

21 **Q. Do you have any information about the results of that follow-up solutions**
22 **analysis?**

1 A. Yes. ISO-NE will present the results of both the *2012 Follow-Up Needs Analysis*
2 and the work it has done for a follow-up of the *2011 Updated Solution Study*
3 *Report* at the July 18, 2012 PAC meeting. On July 12, 2012 ISO-NE posted on its
4 website the Power Point presentation it plans to use in presenting these results.
5 Fortunately, that document does not contain CEII. Accordingly, a copy of the
6 presentation is attached to this testimony as Exhibit A. In this presentation, ISO-
7 NE states (p.2): “The follow-up solutions study confirms that the preferred
8 solution from the February 2012 solution study still meets the identified reliability
9 needs.”

10

11 **Q. When do you anticipate that the follow-up report to the *2011 Updated***
12 ***Solution Study Report* will be issued?**

13 A. The slides for the July 18 presentation state that a draft follow-up solution study
14 addendum will be posted to the PAC website “in the near future” for a 30-day
15 comment period. It is quite possible that this posting will occur before the
16 hearings resume on July 31. Should that be the case, we will file it with the
17 Council when we receive it.

18

19 **Q. What are the changes in the assumptions used in the draft *2012 Follow-Up***
20 ***Needs Analysis*, as compared to those used in the *2011 Updated Needs Report***
21 **(which was actually released in February, 2012)?**

1 A. Changes in assumptions were made to reflect developments in system resources,
2 transmission topology, forecasted loads, and changes in ISO-NE forecasting
3 methodology. The principal changes were as follows:

- 4 • The Capacity, Energy, Loads, and Transmission (CELT) Report for 2012
5 was used to forecast loads. The 2010 CELT report was used for the last
6 needs study.
- 7 • The 2012 CELT incorporates a forecast of energy efficiency measures
8 (EE) through the year 2022. This is a significant change in forecast
9 methodology. In previous studies for NEEWS and other projects, only EE
10 committed for the 3 year Forward Capacity Auction period was modeled.
- 11 • Because the latest study was being done in 2012, the 10-year forecast
12 horizon was re-set to 2022. The year 2020 was used in the last needs
13 study.
- 14 • Resources that cleared the most recent Forward Capacity Auction (FCA
15 #6: Capacity Period June 1, 2015 – May 31, 2016) were modeled in this
16 study, whereas the previous study used the FCA #4 results.
- 17 • Transmission projects with Proposed Plan Application Approvals as of the
18 March 2012 Regional System Plan Project Listing were included to the
19 base case. Some of these projects were approved in the period during
20 which the Interstate Reliability Project was being studied and reassessed
21 and were not included in the prior modeling.
- 22 • The following changes in generation dispatch assumptions were made:
 - 23 ○ On-shore wind-power output was modeled at 100% of its qualified
24 capacity in the export area, but at 5% of qualified capacity in the import
25 area, apparently in order to reflect the likelihood of low wind on a peak
26 hot summer day. In the last study, the qualified capacity value was
27 used in both cases. (“Qualified capacity” is the amount of capacity that
28 has cleared the Forward Capacity Market qualification processes for a
29 relevant period.)
 - 30 ○ Hydro power units were modeled using actual summer outputs
31 documented in ongoing studies (Vermont / New Hampshire, Pittsfield /
32 Greenfield, and Greater Hartford / Central Connecticut reliability
33 studies.) In the prior study, they were modeled at their qualified
34 capacity values.
 - 35 ○ Pumped storage units were kept at 50% of their output for all
36 dispatches, to reflect the limit on their operability due to their limited
37 storage capacity. The last study allowed them to go to 100% of their
38 output when in the exporting area.
 - 39
 - 40
 - 41
 - 42

- 1 ○ The Salem Harbor, AES Thames, Bridgeport Harbor 2, Somerset 6,
2 Somerset Jet 2, Holyoke 6 & 8, Bio Energy, Potter Diesel, and Ansonia
3 generating units were assumed out of service in the base case due to
4 their delist bids, retirement, or interconnection queue withdrawals.
5 These units were all modeled as available in the last needs study.
6
- 7 ○ The Lake Road generating station was modeled as “on” for all stresses.
8 These units were assumed to be out of service for the East to West
9 stressed cases in the last needs study. (The result of this change was to
10 impose less stress on the transmission system east of Lake Road for
11 East to West power transfers.)
12

13

14 **Q. How did the loads modeled in the draft 2012 Follow-Up Needs Analysis**
15 **compare with those modeled in the previous 2011 Updated Needs Report?**

16 **A.** The peak load for each year that was modeled in both the last study and the most
17 recent study was lower, largely because of the inclusion of predicted future
18 energy efficiency measures, which grew to 1,260 MW for the region (including
19 168 MW for Connecticut) by 2022. For instance, the 2019 Summer 90/10 load in
20 New England was 33,225 MW in the 2010 CELT. The same year in the 2012
21 CELT it was 33,040 MW, a reduction of 185 MW. However, because the draft
22 update used a 10-year planning horizon beginning in 2012, it incorporated two
23 more years of predicted load growth. These extra two years, even with a lower
24 forecast, caused an overall increase of 575 MW in system-wide peak load demand
25 in the follow-up study. But the loads were not higher in every sub-region
26 modeled. For instance, in Connecticut, the 2022 modeled load derived from the
27 2012 CELT was 30 MW lower than the 2020 load that had previously been
28 modeled in the *2011 Updated Needs Report*, based on the 2010 CELT. The
29 comparison of the modeled loads is set forth in table 3-5 of the draft *2012 Follow-*

1 *Up Needs Analysis Report*, which is reproduced below as Table 1 of this
2 testimony:

3 **Table 1**

4 **90/10 CELT Load Comparison (without losses)**

State	2020 Load 2010 CELT (MW)	2022 Load 2012 CELT (MW)	Difference (MW)	Difference (%)
Maine	2,500	2,480	-20	-0.80%
New Hampshire	3080	3,120	+40	+1.30%
Vermont	1,255	1,230	-25	-1.99%
Massachusetts	15,575	16,060	+485	+3.11%
Rhode Island	2,300	2,430	+130	+5.65%
Connecticut	8,840	8,810	-30	-0.34%
ISO New England	33,555	34,130	+575	+1.71%

6
7 **Q. Please explain how ISO-NE came to adopt the new methodology of reducing**
8 **future loads by the predicted impact of energy efficiency measures beyond**
9 **the Forward Capacity Market period, and why this predicted EE was not**
10 **modeled in the *Updated Needs Report* that was published in April, 2011, or in**
11 **the *Updated Solution Report* that was published in February, 2012.**

12 **A.** ISO-NE was developing the new EE forecast methodology in parallel with its
13 work on the *2011 Updated Solution Report*. ISO presented a “Proof of Concept”
14 for forecasting future EE to the PAC in November, 2011 and developed a long-
15 term EE forecast which it issued in April 2012. NUSCO was aware of this on-
16 going project, but believed that the new methodology would be applied
17 prospectively, for new projects, and not retroactively to advanced stage projects
18 that had been developed using traditional EE modeling. This turned out not to be
19 the case.

1 In May, 2012 ISO-NE held a PAC meeting for the purpose of considering how
2 the new EE forecast would be used in planning studies. NUSCO, on behalf of the
3 NU operating companies, made a presentation at that meeting suggesting that the
4 new methodology be implemented cautiously and gradually, and that it not be
5 applied in update studies for advanced stage projects such as the Interstate
6 Reliability Project, which had by then been issued an I.3.9 approval. Other
7 transmission owners submitted similar comments. NUSCO also advocated this
8 position to the New England Power Pool Reliability Committee and to the ISO-
9 NE Board of Directors. ISO-NE did not find these comments and presentations
10 persuasive, and completed its Attachment K reanalysis of the Interstate Reliability
11 Project using the new methodology.

12
13 **Q. What was the impetus for ISO-NE's adoption of its new EE forecasting**
14 **methodology?**

15 A. In 2010, The New England States Commission on Energy (NESCOE), which
16 represents the New England states in the PAC, began urging ISO-NE to forecast
17 EE savings beyond the FCM results across the ten-year planning horizon. The
18 New England states have been making large investments in EE through many
19 programs and have committed to continue to do so. NESCOE maintained that in
20 order for consumers to receive the full benefits of their EE investments, expected
21 future EE should be modeled. NESCOE's view prevailed.

1 **Q. What was the basis for NUSCO concerns with respect to the implementation**
2 **of the new EE policy?**

3 A. NUSCO was concerned that there were many uncertainties with respect to the
4 future funding and performance of EE measures that warranted a cautious
5 implementation of the concept, including de-rating the predicted quantities of EE
6 by an appropriate percentage to reflect that uncertainty. NUSCO also considered
7 that if the assumptions in planning analyses were to be changed to include EE
8 measures beyond those that have cleared the FCA, other variables that could be
9 affected by enhanced EE – such as the continued participation of generating units
10 in the FCM – should be considered and modeled. That is, in the traditional
11 planning approach, resources that cleared the latest FCA (both supply resources
12 such as generation and demand resources, such as EE) were held constant through
13 the planning period after the expiration of the three-year FCM commitment
14 period. There was no attempt to predict either growth of EE or retirements of
15 generation units. NUSCO suggested that if this assumption were to be changed
16 for demand resources it should also be changed for supply resources, particularly
17 since the reduction of load associated with the growth of EE can have a “ripple
18 effect” on the economics of generation and thereby contribute to the retirement of
19 marginal units. Finally, NUSCO submitted that application of the new
20 methodology to a project such as this one, which had been studied for over 8
21 years, had received an I.3.9 approval, and was in siting, would be disruptive and
22 risky.

23

1 **Q. Do these concerns affect your evaluation of the draft 2012 Follow-Up Needs**
2 ***Analysis?***

3 A. Not really. If the new EE methodology had not been applied, or had been applied
4 cautiously with a de-rating factor to reflect the uncertainty of all of the EE
5 materializing and the potential of the full EE to cause retirements, the modeled
6 overloads would have been more numerous and more severe. However, the end
7 result would have been the same – the needs that drive the Interstate Reliability
8 Project remain the same.

9

10 **Q. How do the results of the power-flow modeling studies undertaken for the**
11 **draft 2012 Follow-Up Needs Analysis compare to those reported in the 2011**
12 ***Updated Needs Report?***

13 A. The overloads produced by simulating design contingencies were similar to those
14 documented in the *2011 Updated Needs Report*. In particular, in N-1 testing,
15 thermal violations for Eastern New England were found in Rhode Island and on
16 the 115-kV path connecting Rhode Island and Connecticut. In N-1-1 testing there
17 were several thermal and voltage violations, the most severe of which were in
18 Rhode Island, where a voltage collapse could occur. In addition, Eastern New
19 England reliability testing indicated thermal violations on the central and southern
20 345-kV paths connecting Rhode Island to Connecticut and southeastern
21 Massachusetts. Western New England and Connecticut reliability testing
22 indicated thermal violations on the central 345-kV East-West path and 115-kV
23 path connecting Rhode Island and Connecticut along the Long Island Sound

1 shoreline. However, overall, the thermal overloads in the draft *Follow-Up Needs*
2 *Analysis* were somewhat less severe and fewer in number than those identified in
3 the *2011 Updated Needs Analysis*.

4
5 **Q. If the loads modeled in the draft 2012 *Follow-Up Needs Analysis* were**
6 **somewhat higher than those modeled in the *2011 Updated Needs Analysis*,**
7 **even after predicted future EE was accounted for, why were the thermal**
8 **overloads in the later study less severe and numerous?**

9 A. The logical conclusion is that the cumulative effect of the changes to the
10 assumptions other than the modeled loads was to impose less stress on the system.

11
12 **Q. How does the draft 2012 *Follow-Up Needs Analysis* consider the risk of**
13 **retirements of existing resources during the ten-year planning period?**

14 A. The draft *2012 Follow-Up Needs Analysis* assumes that all generators that have
15 cleared FCM #6 and have not sought to de-list, shut down, or announce a
16 retirement plan will be in service throughout the planning period – until 2022. As
17 we explained earlier, ISO-NE did not vary this traditional assumption when it
18 decided to project new EE beyond the three-year FCM horizon. However, the
19 draft report does recognize that there is a risk of additional retirements beyond
20 those assumed, and that such retirements would make the need for the Interstate
21 Reliability Project more pressing. Thus, the draft report states that with
22 generation retirements, the need for additional eastern New England transmission
23 transfer capability, the need for additional western New England transmission

1 transfer capability, and the need for additional transfer capability into Connecticut
2 is advanced.

3

4 **Q. Is there any basis for predicting that some generating units modeled in the**
5 **base case of the draft 2012 Follow-Up Needs Analysis will in fact retire during**
6 **the planning period – before 2022?**

7 A. Yes. Very recent and authoritative analyses have recognized this risk. The most
8 pertinent is the Connecticut Department of Energy and Environmental Protection
9 (DEEP) 2012 Integrated Resource Plan for Connecticut (the *Connecticut 2012*
10 *IRP*), which is Council Administrative Notice Item #38. The *Connecticut 2012*
11 *IRP* identifies both units that it characterizes as now “planned to retire” and
12 additional units that it predicts will be forced to retire by economic pressures
13 resulting from market price changes, the cost of upgrades required to comply with
14 environmental regulations, and other economic factors. In the first category,
15 DEEP, like ISO-NE in the *2012 Follow-Up Needs Analysis*, recognizes the
16 retirement of the Salem Harbor units and the AES Thames plant, and assumes the
17 retirement of the Vermont Yankee nuclear unit. These units represent an
18 aggregate 1,532 MW of capacity. DEEP then goes on to cite a thorough and
19 detailed economic analysis (performed by the Brattle Group) that predicts
20 additional retirements in Connecticut aggregating 938 MW of capacity by 2015,
21 including Middletown Units #2 and #3, Montville Unit #5, New Haven Harbor
22 and Norwalk Harbor Units #1 and #2. DEEP further estimates economic

1 retirements in the rest of the ISO-NE region (outside Connecticut) aggregating
2 1,687 MW by 2016.

3
4 The second authoritative recent estimate was made by ISO-NE itself. Last month,
5 ISO-NE published a “Discussion Paper” entitled *Aligning Markets and Planning*
6 (June, 2012). In this paper, ISO-NE concluded that because of both new
7 environmental regulations and market conditions, it is plausible that over 5,000
8 MW of capacity – a sixth of the region’s existing generation fleet – may
9 permanently shut down over the coming decade. Moreover, ISO-NE noted, many
10 of these resources are situated in key locations on the grid, where their exit could
11 lead to violations of transmission reliability criteria. This capacity includes 10
12 coal-fired generating units with an average age of 47 years and a combined
13 capacity of 2,355 MW and 12 oil-fired (steam) generating units with an average
14 age of 44 years and a combined capacity of 2,661 MW.

15
16 **Q. Does the 2012 Connecticut IRP address the benefits of the Interstate
17 Reliability Project as a hedge against retirements?**

18 A. Yes, DEEP notes in the *2012 Connecticut IRP* (p. 15) that its model results
19 indicate that the Connecticut capacity price would not separate (differ) from the
20 New England capacity price if the NEEWS projects continue to be developed and
21 receive the necessary approvals. In that case, Connecticut could meet its
22 Transmission Security Analysis requirement even if all 2,716 MW of the fossil
23 steam capacity in Connecticut retired. DEEP also stresses that long-range

1 planning analysis must address uncertainty in order to be useful. DEEP stresses
2 that regardless of the effort and attention that goes into the analysis, it is
3 impossible to perfectly predict external factors – such as natural gas prices and
4 economic growth – over which regulators and utilities do not have direct control.
5 (p.28) The margin that will be provided by the Interstate Reliability Project will
6 provide a robust hedge against such uncertainty.

7
8 **Q. Please summarize your current opinion concerning the need for the**
9 **Interstate Reliability Project, taking into account the latest information now**
10 **available to you through the draft 2012 *Follow-Up Needs Analysis*, published**
11 **earlier this month.**

12 A. We concluded our previous testimony by pointing out that numerous studies and
13 re-analyses undertaken from 2004 through 2011 had demonstrated that the
14 Interstate Reliability Project is needed to provide reliable electric service to the
15 Southern New England states of Connecticut, Massachusetts, and Rhode Island,
16 and should be constructed as soon as possible. ISO-NE's latest draft "Follow-
17 Up" analysis confirms this need, notwithstanding that it incorporates a sharp
18 departure from previous practice in assuming the attainment of aggressive energy
19 efficiency in the future. The project should go forward now in order to assure
20 compliance with national and regional reliability requirements and to provide a
21 hedge against capacity retirements that are likely to occur by 2015. We continue
22 to believe that this project is needed for system reliability and represents a sound
23 investment in Connecticut's energy future. We concur with DEEP's conclusion

1 in its June 21, 2012 comment letter to the Council (p.2) that this project is needed
2 and deserves Siting Council approval.

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23