

STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

Jewel Mullen, M.D., M.P.H., M.P.A.
Commissioner



Dannel P. Malloy
Governor

Nancy Wyman
Lt. Governor

December 30, 2014

RECEIVED
JAN 07 2015 10

CONNECTICUT
SITING COUNCIL

ORIGINAL

Ms. Melanie Bachman
Acting Executive Director
Connecticut Siting Council
Ten Franklin Square
New Britain, CT 06051

RE: Docket No.453 – American Tower Corporation and New Cingular Wireless PCS, LLC application for a Certificate of Environmental Compatibility and Public Need for the construction, maintenance, and operation of a telecommunications facility located at Manchester Tax Assessor Maps 133, Block 3700, Lots 701, 701 Lydall Street, Manchester, Connecticut. DPH Project # 2014-0276

Dear Ms. Bachman:

The Drinking Water Section (DWS) of the Department of Public Health has reviewed the location and specific work items associated with the above noted Docket Number. This project is contained within the public water supply watershed of Manchester Water Department (Lydall Reservoir watershed) an active source of public drinking water for the Manchester Water Department (PWSID #CT0770021). The DWS offers the following recommendations to protect this source of public drinking water:

- Erosion and sedimentation controls should be in place and properly maintained as necessary.
- A responsible party should be identified for maintenance, inspection, repair, and replacement and incorporation of new controls as may become necessary.
- Servicing of machinery should be completed outside of the public water supply watershed.
- Refueling of vehicles or machinery should take place on an impervious pad with secondary containment designed to contain fuels.
- Fuel and other hazardous materials should not be stored within the public water supply watershed. Any fuel or hazardous materials that must be kept within the public water supply watershed during working hours should be stored on an impervious surface utilizing secondary containment.
- A fuel spill remediation kit should be stored on-site so that any spills may be contained and cleaned quickly.



Connecticut Department
of Public Health

Phone: (860) 509-7333 • Fax: (860) 509-7359 • VP: (860) 899-1611
410 Capitol Avenue, MS#51WAT, P.O. Box 340308
Hartford, Connecticut 06134-0308
www.ct.gov/dph

Affirmative Action/Equal Opportunity Employer

Melanie Bachman
December 23, 2014
Page 2

- Manchester Water Department should be contacted prior to starting this project to review the scope of this project.
- Manchester Water Department personnel should be allowed to periodically inspect this project to ensure that drinking water quality is not being adversely impacted.

If you have any questions regarding this matter, please contact Mira S. Lami of this office at 860-509-7333.

Sincerely,



Eric McPhee
Supervising Environmental Analyst
Drinking Water Section



Cc: Lori Mathieu, Public Health Section Chief, Drinking Water Section, Department of Public Health