



# STATE OF CONNECTICUT

## CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

[www.ct.gov/csc](http://www.ct.gov/csc)

August 9, 2017

Anthony M. Fitzgerald, Esq.  
Carmody Torrance Sandak & Hennessey LLP  
195 Church Street  
New Haven, CT 06509

RE: **DOCKET NO. 461A** - Eversource Energy application for a Certificate of Environmental Compatibility and Public Need for the construction, maintenance, and operation of a 115-kilovolt (kV) bulk substation located at 290 Railroad Avenue, Greenwich, Connecticut, and two 115-kV transmission circuits extending approximately 2.3 miles between the proposed substation and the existing Cos Cob Substation, Greenwich, Connecticut, and related substation improvements. Reopening of this docket based on changed conditions pursuant to Connecticut General Statutes §4-181a(b).

Dear Attorney Fitzgerald:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than August 22, 2017.

Please forward an original and 15 copies to this office, as well as send a copy via electronic mail. In accordance with the State Solid Waste Management Plan and in accordance with Section 16-50j-12 of the Regulations of Connecticut State Agencies the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Copies of your responses shall be provided to all parties and intervenors listed on the service list, which can be found on the Council's pending proceedings website.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Yours very truly,

Melanie Bachman  
Executive Director

MB/RDM

c: Parties and Intervenors



# STATE OF CONNECTICUT

## CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

[www.ct.gov/csc](http://www.ct.gov/csc)

### Connecticut Siting Council

#### Docket No. 461A

#### Eversource - GSLP Greenwich

#### Pre-hearing Interrogatories – Set 2

62. Referring to July 25 2017, Transcript. p. 127. What was the attendance at the energy efficiency Earth Day event?
63. Referring to July 25 2017, Transcript. p. 158. What percentage of the total project cost is attributed to distribution elements and what percentage of the total project cost is attributed to transmission elements? What percentage of each is borne by Connecticut ratepayers?
64. Reference CSC-01, Q-CSC-061. Is it anticipated that the cost of the architectural treatment of the 281 Railroad Avenue indoor substation and the Town-requested pedestrian bridge would not be regionalized, but rather be borne by Connecticut ratepayers?
65. Reference CSC-01, Q-CSC-057. Revise table to only include the AMP with variations, including revisions after the table was submitted. Include a new row to include the cost variation of extending the transmission line to the 290 Railroad Avenue Substation location.
66. Referring to July 25 2017, Transcript. pp. 37-38. Provide more detail on the feasibility of extending the transmission line either overhead or underground along the south side of Interstate 95 between the commuter parking lots on Sound Shore Drive and Indian Field Road.
67. Regarding both proposed substations, would any trees on abutting properties require removal to meet NERC substation clearance standards?
68. Referring to July 25 2017, Transcript. pp. 76-77. Estimate the number of feet that the 281 Railroad Avenue Substation brick wall could be pulled back from the sidewalk facing Railroad Avenue.