



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

VIA ELECTRONIC MAIL

August 16, 2016

Kenneth C. Baldwin, Esq.
Robinson & Cole LLP
280 Trumbull Street
Hartford, CT 06103-3597

RE: **DOCKET NO. 462** – Celco Partnership d/b/a Verizon Wireless application for a Certificate of Environmental Compatibility and Public Need for the construction, maintenance, and operation of a telecommunications facility located at Danbury Tax Assessor's Map L16, Lot 5, 15 Great Pasture Road, Danbury, Connecticut.

Dear Attorney Baldwin:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than August 23, 2016. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 15 copies to this office, as well as send a copy via electronic mail. In accordance with the State Solid Waste Management Plan and in accordance with Section 16-50j-12 of the Regulations of Connecticut State Agencies the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Copies of your responses shall be provided to all parties and intervenors listed on the service list, which can be found on the Council's pending proceedings website.

Yours very truly,

Melanie Bachman
Acting Executive Director

MB/MP

c: Parties and Intervenors
Council Members

Docket No. 462
Development and Management Plan Interrogatories
August 16, 2016
Set One

1. Provide the following information for the backup generator:
 - a) Size in kilowatts;
 - b) Run time in hours based on the proposed 1,000-gallon propane tank; and
 - c) Indicate that the generator is for Cellco's own use.
2. Is Cellco also proposing its battery backup system to be installed on the equipment pad? Would it have a run time of approximately four to eight hours?
3. While the proposed underground utilities are not located within the Department of Energy and Environmental Protection's (DEEP) Dig Restricted Area (DRA), provide the maximum depth of the proposed utility trench, and estimate the DRA depth per condition 2a of the Connecticut Siting Council's Decision and Order dated December 10, 2015. Did Cellco Partnership d/b/a Verizon Wireless (Cellco) seek to maximize the horizontal distance from the DRA to the utility trench as well?
4. Given the proposed "open canopy" equipment pad design in the Development and Management Plan (D&M Plan), is it correct to say that no air conditioning units are required? Does Cellco expect that the new "open canopy" design with outdoor radio equipment would still meet applicable noise standards at the property boundaries? The original noise analysis was performed based on an enclosed equipment shelter with two air conditioning units on the outside. (The backup generator can be neglected as a device related to an "emergency" under the Regulations of Connecticut State Agencies §22a-69-1.8.)
5. Would the Erosion and Sedimentation Control plan comply with the *2002 Connecticut Guidelines for Soil Erosion and Sedimentation Control*?
6. Provide the proposed construction hours and days of the week, e.g. Monday through Friday 7am to 5pm. If the D&M Plan is approved, approximately when would construction commence and when would construction be completed?
7. Referencing Sheet C-4 of the D&M Plan, would the proposed 1.5-inch maximum gap under the fence prevent turtle entry and/or reduce risk of entrapment after construction is complete?