



56 Prospect Street
P.O. Box 270
Hartford, CT 06141-0270

Kathleen M. Shanley
Manager – Transmission Siting
Tel: 860-728-4527

July 13, 2018

Mr. Robert Stein, Chairman
Connecticut Siting Council
Ten Franklin Square
New Britain, CT 06051

RE: Docket No. 466: Frost Bridge to Campville 115-kV Project
Monthly Construction Progress Report – June 2018

Dear Chairman Stein:

Pursuant to RCSA Section 16-50j-62(b)(3) and as described in Volume 1, Section 7, of the *Development and Management ("D&M") Plans for the Frost Bridge to Campville 115-kV Project ("Project")*: *D&M Plan for New 115-kV Transmission Line and Related Transmission Line Modifications* and the *D&M Plan for Modifications to the Frost Bridge Substation and Campville Substation*, The Connecticut Light and Power Company doing business as Eversource Energy (Eversource) hereby provides to the Connecticut Siting Council ("Council") this Construction Progress Report for the month of June 2018.

Should you or other Council members have any questions regarding this submission, please do not hesitate to contact me via e-mail at kathleen.shanley@eversource.com or telephone at (860) 728-4527.

Sincerely,

A handwritten signature in blue ink, appearing to read "Kathleen M. Shanley".

Kathleen M. Shanley

Enclosure

DOCKET NO. 466
FROST BRIDGE TO CAMPVILLE 115-kV PROJECT
MONTHLY CONSTRUCTION PROGRESS REPORT
JUNE 2018

1. NEW 115-kV TRANSMISSION LINE AND RELATED TRANSMISSION LINE MODIFICATIONS

During June, crews continued to perform restoration and final stabilization work along the transmission line right-of-way (ROW). In addition, along the new transmission line in the Town of Watertown, Eversource conducted subsurface investigations of the backfill material on certain direct embed structure foundations and implemented backfill replacement/remediation as required; on Structure 5, permanent guy wires were installed.¹

Eversource also continued to perform routine inspections to verify the integrity of erosion and sedimentation controls and to monitor the restoration work.

2. MODIFICATIONS TO FROST BRIDGE AND CAMPVILLE SUBSTATIONS

All Project modifications to both Frost Bridge Substation and Campville substations were completed as of the end of May 2018. The landscaping installed outside the fence line at Frost Bridge Substation (pursuant to Condition 2.d of the CSC's Decision and Order) is being monitored.

3. MINOR DEVELOPMENT & MANAGMENT (D&M) PLAN CHANGES

No minor D&M Plan changes were identified in June 2018.

¹ Work performed pursuant to Eversource's D&M Plan Change Notice Request dated June 21, 2018 and the Council's approval, also dated June 21, 2018.