


May 31, 2018

Mr. Robert Stein, Chairman
Connecticut Siting Council
Ten Franklin Square
New Britain, CT 06051

ORIGINAL



RE: Docket No. 466: Frost Bridge to Campville 115-kV Project
Notification of Commencement of Operation: Campville Substation Modifications for 1191
and 1921 Line Separation

Dear Chairman Stein:

Pursuant to Section 16-50j-62(b)(4) of the Regulations of Connecticut State Agencies (RCSA), Condition 11 of this Docket, and Section 7.1 of the *Frost Bridge to Campville 115-kV Project (Project Development and Management (D&M) Plan for the Modifications to the Frost Bridge Substation and Campville Substation*, The Connecticut Light and Power Company doing business as Eversource Energy (Eversource) hereby informs the Connecticut Siting Council (Council) that the Project-related equipment modifications at Campville Substation to finalize the separation of the 1191 and 1921 115-kV transmission lines have been completed.

These modifications included the removal and replacement of the existing 2T breaker with the new 2T-A PASS GIS breaker and associated equipment installation. After the completion of these modifications, the entire substation was placed back into service on May 7, 2018.

With the completion of the 1191 and 1921 Line modifications within Campville Substation, all Project components have been energized.¹

Should you or other Council members have any questions regarding this submission, please do not hesitate to contact me via e-mail at kathleen.shanley@eversource.com or telephone at (860) 728-4527.

Sincerely,

Kathleen M. Shanley

¹ As Eversource identified in correspondence to the Council dated December 20, 2017, all of the new 115-kV facilities, including the 1854 Line and associated modifications at Frost Bridge and Campville substations, were energized and placed into service on December 16, 2017.