

STATE OF CONNECTICUT

SITING COUNCIL

<p>DOCKET NO. 468 - The Connecticut Light & Power Company d/b/a Eversource Energy application for a Certificate of Environmental Compatibility and Public Need for the Southwest Connecticut Reliability Project that traverses the municipalities of Bethel, Danbury, and Brookfield, which consists of (a) construction, maintenance and operation of a new 115-kV overhead electric transmission line entirely within existing Eversource right-of-way and associated facilities extending approximately 3.4 miles between Eversource's existing Plumtree Substation in the Town of Bethel to its existing Brookfield Junction in the Town of Brookfield; (b) reconfiguration of two existing 115-kV double-circuit electric transmission lines at Eversource's existing Stony Hill Substation in the Town of Brookfield; and (c) related substation modifications</p>	<p>DOCKET NO. 468</p> <p>September 15, 2016</p>
--	--

DIRECT TESTIMONY OF JULIA FRAYER ON BEHALF OF THE CONNECTICUT LIGHT AND POWER COMPANY DOING BUSINESS AS EVERSOURCE ENERGY CONCERNING NON-TRANSMISSION ALTERNATIVES TO THE SOUTHWEST CONNECTICUT RELIABILITY PROJECT

1 **Q. Please state your name, business affiliation and business address for the record.**

2
3 **A.** My name is Julia Frayer. My firm's name is London Economics International LLC. My
4 offices are located at 717 Atlantic Avenue in Boston, Massachusetts.

5 **Q. What is your position with London Economics International?**

6
7 **A.** I am a Managing Director at London Economics International and lead many of the firm's
8 consulting engagements involving market analysis and infrastructure evaluation. This is
9 the business area under which the subject matter of non-transmission alternatives
10 ("NTAs") falls.

11 **Q. What has been your role on the project?**

12
13 **A.** I managed and oversaw an economic analysis of NTAs for the Southwest Connecticut
14 Reliability Project ("Project"). The methodological approach for this analysis as well as
15 study findings were documented in a report, entitled *Analysis of the Feasibility and*
16 *Practicality of Non-Transmission Alternatives ("NTAs")*, dated March 11, 2016. A copy
17 of the report is provided as Exhibit 4 in Volume 4 of Eversource's application in this
18 Docket.

19 **Q. Were all materials that bear your name prepared by you or under your**
20 **supervision?**

21
22 **A.** Yes.

23
24 **Q. Do you have any additions or corrections to your report?**

25 **A.** Yes, I have one correction and one clarification. Both footnote 4 on page 12 and
26 Figure 15 on page 33 state that a capacitor bank is a more expensive option for generating
27 reactive power, as compared to a synchronous condenser. Even though a synchronous
28 condenser is in fact the more expensive option, this does not change the NTA analysis in

29 our report because, for purposes of our analysis, a synchronous condenser is needed to
30 provide the ability to absorb and inject reactive compensation to control local area
31 voltages.

32 The clarification concerns Figure 1, Row 5 on page 7, and Figure 8, Row 5 on page 20 of
33 the report. Both of these line items refer to one of the transmission solution components
34 for the Housatonic Valley sub-area identified in the *ISO-NE Solutions Report* as, “The
35 substation fence will be expanded”. The description of this work should have also
36 referred to the installation of a synchronous condenser at Stony Hill Substation, which
37 results in the need to expand the substation fence line.

38 **Q. Can you describe the NTA analysis you performed?**

39
40 **A.** As the starting point for LEI’s analysis, Eversource system planners identified quantities
41 of injections of power into the electrical system that would be required at particular
42 electrical locations in the Housatonic Valley sub-area in order to eliminate the need for
43 regulated transmission improvements in this sub-area. Eversource did not determine the
44 types of resources and technology that could provide such injections or reductions of
45 demand at each location; LEI made that determination. Such a determination requires
46 consideration of the suitability of the available technologies for the particular application,
47 including performance characteristics, cost, land requirements, and access to cooling
48 water (if necessary), availability of fuel supplies, and other factors for developing and
49 bringing to commercial operation a new demand reduction program or supply-side
50 resource. Eversource planners also did not undertake to estimate the cost of the NTA
51 solutions to be compared to the cost of the transmission solution. LEI performed all
52 analyses regarding the suitability of available technologies and the cost of such

53 technologies.

54 Eversource planners also determined that demand-side resources alone could not properly
55 address thermal overloads and voltage violations observed in the sub-area and, as such,
56 could not be a technically viable alternative to the proposed transmission solution.
57 Supply-side resources alone, however, could potentially qualify as technically feasible
58 alternatives to the proposed solution.

59 **Q. What information did Eversource provide to LEI regarding the quantity and**
60 **locations of NTAs that would be needed?**

61 Eversource identified the quantity and locations of NTAs that would alleviate both
62 thermal system overloads and voltage violations in the sub-area. Specifically, Eversource
63 planners determined that a total injection of 247 MW of power over four locations (50
64 MW at Stony Hill Substation; 47 MW at West Brookfield Substation in Brookfield; 50
65 MW at Triangle Substation in Danbury; and 100 MW at Peaceable Substation in
66 Redding) would be required to alleviate reliability needs in the sub-area in lieu of the
67 planned transmission upgrades. In addition to the active power requirements (MW),
68 Eversource planners determined that these locations also require reactive power
69 regulation of up to 16 MVAR (Stony Hill and Triangle substations), 15 MVAR (West
70 Brookfield substation), and 33 MVAR (Peaceable substation).

71 Using these assumptions provided by Eversource, we examined what actual supply-side
72 resources – whether alone or in combination with demand-side resources - could provide
73 these energy injection amounts, and selected hypothetical technically feasible NTA
74 technologies for cost analysis, based on performance relative to planning criteria and size.
75 “Technically feasible technologies” are those technologies that could hypothetically be

76 implemented based on planning criteria and technology-specific operating profiles. A
77 technically feasible NTA technology therefore meets the reliability issues being addressed
78 by the proposed transmission components and is then a candidate for cost analysis. A
79 technically feasible NTA solution may still not be practical and may face numerous
80 challenges in commercialization which we discuss in our report. The results of our
81 studies, as well as a detailed description of their analyses, are contained in our report.

82 **Q. Please summarize the analysis and findings in your report.**

83 **A.** Using the assumptions provided by Eversource, we considered two “cases” in our
84 analysis: (i) an NTA solution solely based on supply-side resources (“Supply Case”) and
85 (ii) an NTA solution combining both demand and supply-side resources (“Combination
86 Case”). In light of the determination by Eversource planners that demand-side resources
87 alone would not be sufficient to address reliability concerns, we decided to include a
88 Combination Case in the alternative analysis to determine whether combining both
89 demand and supply-side resources would lower the costs associated with an NTA
90 solution.

91 In both the Supply Case and the Combination Case, we identified supply-side resources,
92 including slow discharge batteries, peaker aeroderivatives, and fuel cells, as technically
93 feasible NTA technologies at all four substations serving as the injection points. The
94 assessment of technical feasibility included the ability to provide reactive power
95 instantaneously. In the Combination Case, energy efficiency resources (limited to load
96 availability and load reduction capability) were assumed by default to be part of the NTA
97 solution, and as such would cover a portion of the megawatt requirement, while a supply-
98 side resource would address the remainder of the energy requirement, as well as provide

99 reactive power to ameliorate voltage issues. Some technologies, such as gas-fired
100 aeroderivative peakers feature this capability by design; however, providing reactive
101 power instantaneously would require the plant to be constantly running. We assumed that
102 all the considered technologies (including engine-based technologies such as gas-fired
103 generation) would need to be accompanied by a synchronous condenser to address the
104 instantaneous nature of the voltage requirement. Although we explored the technical
105 feasibility of solar photovoltaic (PV) as a NTA at the considered locations, such
106 technology was excluded from the analysis due to cost, the volume of nameplate capacity
107 needed, and the associated land requirements.

108 We then assessed whether the technically feasible NTAs could be cost-effective and
109 practical, employing industry-standard levelized costing principles to select the least-cost
110 NTA technology for each location from the group of technically feasible NTA
111 technologies. Since no merchant sponsor has proposed to build the NTAs, and the NTAs
112 would not generate a return that would attract private investors, we assumed that they
113 would be built only if their net costs were paid for by electric ratepayers. We estimated
114 the net direct cost of the NTAs to Connecticut ratepayers by deducting expected average
115 annual market-related revenues from levelized annual gross costs of investment
116 (including capital and operating costs).

117 The tables below summarize the total requirements and technically feasible NTA
118 technologies, by substation:

119

120

121
122
123

Supply Case - List of Qualified Technologies and Requirements for Each Substation

Substations	Stony Hill	West Brookfield	Triangle	Peaceable
Requirements at substation (MW)	50	47	50	100
Requirements at substation (MVAR)	16	15	16	33
NTA Technologies (nameplate rating):				
Aeroderivative Peaker (MW)	59	55	59	118
Synchronous Condenser (MVAR)	25	25	25	50

124
125
126
127
128
129

Note: Capacity of NTA technologies were sized to reflect requirements and performance of the selected NTA technology as well as minimum scale constraints if any.

Combination Case - List of Qualified Technologies and Requirements for Each Substation

Substations	Stony Hill	West Brookfield	Triangle	Peaceable
Requirements at substation (MW)	50	47	50	100
Requirements at substation (MVAR)	16	15	16	33
NTA Technologies:				
Energy Efficiency (MW)	8	7	10	5
Aeroderivative Peaker (MW)	49	47	48	111
Synchronous Condenser (MVAR)	25	25	25	50

130
131
132
133
134
135
136
137
138
139
140
141

We determined that the least-cost NTA solution was the Supply Case, which would entail the development of 291 MW of gas-fired peakers (using aeroderivative technology) across four locations (and each of the peaking facilities would include a synchronous condenser for voltage regulation) at a direct cost to electric ratepayers totaling \$53 million per year. By comparison, the direct cost to electric ratepayers for the Combination Case (combining 31 MW of incremental energy efficiency resources and 255 MW of supply-side NTA technologies) was estimated at \$82 million per year.

The direct cost to electric ratepayers under both the Supply Case and the Combination Case would be significantly more than the \$2.1 million per year estimated by Eversource as the Connecticut electric ratepayers allocated share of the annual revenue requirement

142 associated with the transmission solution for the Housatonic Valley sub-area, as identified
143 in the *SWCT Solutions Report*. This enormous cost differential compelled the conclusion
144 that an NTA – neither the Supply Case nor the Combined Case - would not provide a
145 practical alternative to the transmission solution.

146 **Q. Did you consider other issues associated with the development of the Supply Case**
147 **and Combined Case?**

148 **A.** Yes, as noted in our report, we considered that additional costs would be associated with
149 the development of these NTAs. For example, for any new NTA involving a gas-fired
150 generator, new natural gas pipeline laterals would have to be constructed between the
151 existing gas pipelines and the four substations¹ where gas-fired generation units would be
152 needed. Similarly, the NTA estimates above do not include the cost of any electric
153 transmission system upgrades that may be required to interconnect the NTA technologies.
154 Such further studies would have to evaluate the costs of interconnection and refine the
155 estimated amount of power required (and design of the NTA) and would also have to
156 consider a full range of the non-economic costs and benefits of the NTAs, compared to
157 those of the transmission solution. For instance, the environmental effects of the NTAs
158 (e.g., noise impacts and air emissions from the aeroderivative and combined cycle gas
159 turbine [CCGT] plants) would have to be specifically determined and subsequently
160 compared to those of the transmission alternative, which are extensively described in the
161 Application (refer to Section 6). In addition, forward-looking simulation modeling would
162 have to be performed to assess the relative longevity of both the transmission solution and

¹ Although Stony Hill Substation is located comparatively near a natural gas pipeline (less than 0.1 mile), the West Brookfield Substation is about 1.3 miles from the nearest gas pipeline, while Triangle Substation and Peaceable Substation are located 1.5 miles and 8.2 miles, respectively, from the nearest gas pipelines.

163 the potential NTA technologies, and to compare the various services and other benefits
164 that each could provide.

165 In fact, the least cost technically feasible NTA solution was estimated to cost Connecticut
166 ratepayers significantly more than the portion of the annual cost of the transmission
167 solution payable by Connecticut end-use customers. Furthermore, there are a host of
168 practical impediments to developing and bringing to fruition an NTA solution. There are
169 also questions related to the development process itself, as no private developer to date
170 has shown interest in bringing to market an NTA that would fit the technological
171 requirements and geographical requirements of the necessary NTA solution. Based on
172 these findings, I could not conclude that there was a viable, cost effective alternative to
173 the Project.

174 **Q. Has there been any new information that could possibly change any inputs or**
175 **assumptions in your analysis?**

176 **A.** Markets are constantly evolving. Although we had considered market information from
177 FCA 10, and information from state filings regarding cost of energy efficiency from
178 December 2015, other inputs into our analysis have not been updated since 2015.
179 However, I don't believe this will materially impact the report's overall findings
180 regarding the big differential between the levelized costs of a potential NTA solution
181 relative to the transmission solution or otherwise reduce the practical challenges of
182 bringing forth an NTA.

183 **Q. Does that conclude your testimony?**

184 **A.** Yes