



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

VIA ELECTRONIC MAIL

November 7, 2019

Kenneth C. Baldwin, Esq.
Robinson & Cole LLP
280 Trumbull Street
Hartford, CT 06103-3597

RE: **DOCKET NO. 481** - Cellco Partnership d/b/a Verizon Wireless Certificate of Environmental Compatibility and Public Need for the construction, maintenance, and operation of a telecommunications facility located at 667, 665, 663 and 663R Main Street, Cromwell, Connecticut.

Dear Attorney Baldwin:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than November 21, 2019. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 15 copies to this office, as well as send a copy via electronic mail. In accordance with the State Solid Waste Management Plan and in accordance with Section 16-50j-12 of the Regulations of Connecticut State Agencies the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Please be advised that the original and 15 copies are required to be submitted to the Council's office on or before the November 21, 2019 deadline.

Copies of your responses shall be provided to all parties and intervenors listed on the service list, which can be found on the Council's website under the "Pending Matters" link.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

Melanie Bachman
Executive Director

MB/MP

c: Parties and Intervenors

Docket No. 481
Development and Management Plan Interrogatories
November 7, 2019

1. In Cellco Partnership d/b/a Verizon Wireless' (Cellco) Development and Management Plan (D&M Plan) dated October 31, 2019, would the erosion and sedimentation control measures be consistent with the 2002 Connecticut Guidelines for Soil Erosion and Sediment Control per Condition 2(c) of the Decision and Order (D&O)?
2. Condition 2(c) of the D&O includes "water drainage and stormwater control" plans. What design measures and/or features, if any, in the D&M Plan drawings take into account water drainage/stormwater control?
3. Referencing the Valmont Structures calculations, page 31, Fall Zone Letter, it states, "In addition, our monopoles can be designed to theoretically fail at approximately 85-ft AGL by purposely over designing the pole sections below this point..." Was Cellco's approved monopole designed with this feature?