## STATE OF CONNECTICUT CONNECTICUT SITING COUNCIL

IN RE:

REOPENING OF FINAL DECISIONS : DOCKET NO. NT-2010

PURSUANT TO C.G.S. § 4-181A(B) FOR
JURISDICTIONAL NATURAL GAS-FIRED

ELECTRIC GENERATING FACILITIES UNDER C.G.S. § 16-50i(a)(3) AND C.G.S. § 16-50k(a) LIMITED TO COUNCIL CONSIDERATION OF

CHANGED CONDITIONS AND THE

ATTACHMENT OF CONDITIONS TO THE

CERTIFICATES AND DECLARATORY

RULINGS CONSISTENT WITH THE FINDINGS
AND RECOMMENDATIONS IN THE FINAL

REPORT ISSUED BY THE KLEEN ENERGY
PLANT INVESTIGATION REVIEW PANEL

(NEVAS COMMISSION) AND THE FINDINGS AND RECOMMENDATIONS IN THE

EXECUTIVE REPORT ISSUED BY THE

THOMAS COMMISSION : NOVEMBER 16, 2010

# SUPPLEMENTAL RESPONSES OF KIMBERLY-CLARK CORPORATION TO CONNECTICUT SITING COUNCIL PRE-HEARING INTERROGATORY NO. 1

Kimberly-Clark Corporation ("KC") offer the following supplemental information in response to Connecticut Siting Council Interrogatory No. 1 in the above-captioned docket.

#### Question No. 1

If the facility has already been constructed, what versions of the NFPA standards were utilized?

#### Response

The construction of the Kimberly Clark Co-Generation facility (the "Facility") was completed during the 2007-2008 timeframe. Project plans were developed in accordance with the standards in place at that time. Kimberly Clark has asked its project design engineers for

more specific information about the NFPA standards utilized during construction of the Facility.

That information will be provided to the Council as soon as it is available.

#### **Supplemental Response**

The natural gas piping at the KC Facility was constructed in accordance with NFPA 54, National Fuel Gas Code and 49 CFR 192, Transportation of Natural Gas and Other Gas by Pipeline, Minimum Federal Safety Standards.

### **CERTIFICATE OF SERVICE**

I hereby certify that on this  $16^{th}$  day of November 2010, a copy of the foregoing was sent via electronic mail and regular mail to all participants of record.

Kenneth C. Baldwin